

DIGITAL FIRE PROTECTION

THE ROLE OF TECHNOLOGY
IN SERVICE VALIDATION &
COMPLIANCE MANAGEMENT
AT TALL BUILDINGS / HIGH RISES

AGENDA











COMPANY

SERVICES

COMPLIANCE

TECHNOLOGY

Q&A



ABOUT US

90+ Years of Safety, Reliability & Innovation

- Fourth-generation full-service fire protection company Uninterrupted design, installation, inspection, maintenance, testing, and repair services for over 90 years
- 100+ Years Experience in All Aspects of Fire Protection In-house expertise on wet/dry systems, special hazards, foam, fire extinguisher and fire alarm systems
- Over 5,000 Construction Projects Completed
- Largest Fire Protection Shop in the Northeast 80,000 square feet facility, 25 Full Time Engineers, 400+ Employees
- 24/7 Emergency Service Nationwide



1933: Our first Master Plumber license issued to founder Charles Israel

Today, we deploy **REDi**, the most intelligent service validation and code compliance technology available, differentiating us as a pioneer in digital fire protection.





SERVING COMMERCIAL & RESIDENTIAL SITES FOR 90+ YEARS











VORNADO

RADIO CITY HUSSE

Brookfield

jetBlue

Mount

Goldman Sachs

Sinai

5 NATURAL HISTORY

Rudín



OUR SERVICES

ALL OF YOUR FIRE PROTECTION SERVICES FROM ONE TRUSTED SOURCE



INSPECTIONS, TESTING, MAINTENANCE & REPAIRS



FIRE ALARM & SPECIAL HAZARD SYSTEMS



PORTABLE FIRE EXTINGUISHERS SALES & SERVICE



COMMERCIAL KITCHEN FIRE SUPPRESSION, BACKFLOW PREVENTION DEVICE TESTING & HOOD CLEANING




DESIGN, ENGINEERING, FABRICATION & INSTALLATION





NFPA 25 INSPECTIONS, TESTING, MAINTENANCE & REPAIRS





Certifications

NFPA 25 COMPLIANCE TESTING

NFPA 72 COMPLIANCE TESTING

NFPA 2001 ROOM INTEGRITY TESTING



Sprinkler & Standpipe

Pre-Action & Clean Agent Systems

Fire Pump Testing

Kitchen Hood Fire Suppression
Systems

Sprinkler Leaks & Repairs

24/7 Emergency Service

AHJ 5 Year Testing





FIRE ALARMS & SPECIAL HAZARD SYSTEMS









NICET Certified Specialists



NFPA 72 & AHJ Compliance Testing & Reporting



NFPA 2001 Room Integrity Testing



Factory Authorized Distributor for: Autocall, Ansul, Xtralis, Stat-X, Potter, Notifier, NAPCO, Viking & more



ARC Systems



Clean Agent Systems (FM-200, Inergen, NOVEC-1230, Halon)



Elevator MER Aerosol Suppression Systems



Emergency & Exit Light Testing






PORTABLE FIRE EXTINGUISHERS











Authorized retailers for a multitude of fire extinguisher brands including **Amerex, Badger, Buckeye**, and **Ansul**

Including Purple K Extinguishers for E-Bike Fires

Recondition Fire Extinguishers for Construction Sites

Approved Repair/Refill Station: Inspected Annually















Test, Inspect and Maintain Commercial Kitchen Fire Suppression Systems to NFPA Standards



Authorized **Ansul®**, **PyroChem** and **RangeGuard** Distributors



Kitchen Fire Suppression System Backflow, Hood & Duct Cleaning



Kitchen Fire Suppression System Violation Removal




Kitchen Fire Suppression System Hood & Duct Design/Installation





KITCHEN EXHAUST SYSTEM HOOD CLEANING – ALL BRANDS





Removing grease and flammable material from kitchen exhaust hood to bare metal

Covering sensitive equipment and cleaning surrounding kitchen area


- Hoods/Fans/Ducts
- Fan and Belt Repairs
- Filter Replacements
- Hinge Kits
- Access Panels
- Roof Protection Systems / Grease Containment Systems







- Over 5,000 Completed Construction Projects
- Rebuilt World Trade Center Fire Suppression System, Post 9/11
- First Air System (b/c of Deutsche Bank fire)
- First Combo Standpipe
- Only fire protection company in NYC certified to install and service ABCV valves (World Trade Center)



- Fabrication Control of fabrication ensures work is on time and to specification.
 Fabrication via domestic in-house production allows us to manage the entire process
- Installation High-quality installation services keep development timelines on schedule and fully integrated with other simultaneous work processes



NYC BASED - NATIONAL REACH




RAEL self-performs in the NY Metro area and our network of RAEL-Certified Affiliates provide the coverage and the capabilities you need nationwide.

- Fire Sprinkler Inspections
- Fire Alarm Inspections
- Fire Extinguishers
- Emergency Exit Light Testing
- Commercial Kitchen Suppression Systems Inspection and Testing
- Backflow Prevention Device Testing
- Quarterly/ Monthly Hood and Duct Exhaust Cleaning
- AED Sales and Service










REDI FOR THE FUTURE

SERVICE VALIDATION & COMPLIANCE ASSURANCE PLATFORM

COMPLIANCE IS COMPLEX

Inspection, Testing and Maintenance requirements differ across systems & even components.

Many systems have components that require different frequencies for inspections, testing and maintenance - difficult to track.





COMPLIANCE IS COMPLEX

Requirements differ across regions, states, and jurisdictions

All local fire codes abide by national regulations as a baseline often adding their own requirements





COMPLIANCE IS DEMANDING

More than 550 Authorities Having Jurisdiction (AHJs) now require inspections, testing and maintenance reporting to be managed through compliance engines.



Partnership with **MG Engineering Philip F. Parisi Jr., P.E., LEED AP**RAEL National Code Compliance Director





NFPA 25 REQUIREMENTS



NFPA25 CODE REQUIREMENTS

FOR VISUAL INSPECTIONS



Monthly: Fire Sprinkler Systems

- Gauges (Wet, Dry, Pre-action, and Deluge Systems)
- Valves, Valve Components, Trim Inspections Locked/Supervised Control Valves
 - o Alarm Valves (Exterior Bells)
- o Dry Pipe, Deluge, Pre-action Valves Backflow Prevention Assemblies
- o Double Check Valves
- o Control Valves (Locked/Supervised) Standpipe
 - o Control Valves (Locked/Supervised)
- o Gauges (Automatic Dry Standpipes with Air Pressure Supervision)
- Private Fire Service Mains
- o Hose Houses

Quarterly: Fire Sprinkler Systems

- Waterflow Alarm and Signaling Devices, including Mechanical Devices (i.e. Water Motor Gongs)
- Valve Supervisory Signal Devices
- Supervisory Signal Devices (except Valve) Supervisory Switches)
- · Gauges (Wet Pipe Systems)
- Fire Department Connections
- Pressure Reducing and Relief Valves
- Hydraulic Design Information Sign
- Backflow Prevention Assemblies

Semi Annually: Fire Sprinkler Systems NFPA 25

- Private Fire Service Mains
- Monitor Nozzles

Annually: Fire Sprinkler Systems NFPA 25

- · Pipe and Fittings (from floor)
- · Hangers/Seismic Bracing (from floor)
- Sprinklers (from floor)
- Spare Sprinklers
- Hydraulic Design Information Sign
- Information Sign
- Standpipe
- o Piping
- o Hose Racks
- o Hose Connections/Hose Valves
- o Hose/Hose Nozzles · Valves, Valve Components, Trim
- o Interior Dry, Deluge, Pre-action
- o Pressure Reducing Valves
- Private Fire Service Mains
 - o Hydrants
 - o Main Line Strainers



NFPA25 CODE REQUIREMENTS

FOR FUNCTIONAL **TESTING**



Quarterly: Fire Sprinkler Systems

- Mechanical Water Flow Devices
- . Tank High and Low Alarms that do not Report to a Fire Panel that is Monitored 24 Hours a Day
- Valves, Valve Components Hose valves/PRV's
 - o Main Drain (with Backflow Device)

 - o Low Air Pressure Alarms Quick Opening Devices
 - o Priming Water o Master PRV Main Drain

Semi Annually: Fire Sprinkler Systems

NFPA 25 High/Low Tank Alarms

Annually: Fire Sprinkler Systems

- NFPA 25 Main Drain
- Antifreeze Solution
- · Valves, Valve Components
 - Pressure Reducing Valves/Relief Valves (part flow)
 - o Master Pressure Reducing Valves (full flow) Control Valves
 - o Dry System, Partial Trip Test o Deluge, Pre-action Full Trip Test
- o Air Maintenance Device
- Backflow Prevention Assemblies Full Forward Flow Test
- Private Fire Hydrant
- Standpipe o Main Drain Test
 - Hose Valves

 - Valves (all types)

- Private Fire Service Mains
 - Monitor Nozzles Hydrants
- Fire Pump System o Full Flow
- o Alarm Signals Annual Maintenance

5 Year Interval: Fire Sprinkler Systems

NFPA 25

- · Gauges (Test or Replace)
- Sprinklers Extra-High Temperature/Corrosive Atmosphere
- Internal Pipe Obstruction Inspection
- Fire Department Connections Hydrostatic Test Siamese Connections
- Standpipe Full Flow Test Remote Point Hose Connection Pressure Reducing Valves
- Hydrostatic Test Manual/Dry Standpipes . 5 Year Test for new fire hoses and every 3 years
- thereafter Valves, Valve Components
- Pressure Reducing Valves/Relief Valves (full flow)
- Private Fire Service Mains o Full Flow Test
- Internal Tank Test • Internal Backflow & Re-test
- 10 Year Interval & Greater: Fire Sprinkler Systems NFPA 25

Dry Type At: 10 years and every 10 years thereafter Quick Response At: 20 years and every 10 years

Standard At: 50 years and every 10 years thereafter



NFPA 72 REQUIREMENTS



Semi Annually: Automatic Fire Alarm NFPA 72 // ULC 5536

- Control Unit Trouble Signals
- Emergency Voice Alarm Communications Equipment
- Remote Annunciators
- Batteries
- o Sealed Lead-Acid Initiating Devices
- o Air Sampling Smoke Detectors
- o Duct Smoke Detectors
- o Electromechanical Releasing Devices
- o Fire Extinguishing System(s) Switches o Suppression System(s) Switches
- o Fire Alarm Boxes (Pull Stations)
- o Heat Detectors
- o Smoke Detectors
- o Interface Equipment
- o Alarm Notification Appliances -Supervised
- · Supervising Station Fire Alarm Systems -
- Transmitters DACT

Annually: Automatic Fire Alarm NFPA 72 // ULC 5536

Control Equipment:

- · Primary (Main) Power Supply
- Radiant Energy Fire Detectors
- Supervisory Signal Devices
- Waterflow Devices



- Fire Alarm Systems Unmonitored for Alarm, Supervisory, and Trouble Signals
- Interfaced Equipment
- Lamps and LEDS



Semi Annually: Automatic Fire Alarm NFPA 72 // ULC 5536

Control Equipment: Building Systems Connected to Supervising Station

- Functions, Fuses, Interface Equipment, Lamps &
- . LEDs, Primary (main) Power Supply, Transponders Batteries: Fire Alarm Systems
- · Control Unity Trouble Signs

Emergency Voice & Alarm Communication Equipment

- Remote Annunciators
- Initiating Devices
- Duct Smoke Detectors
- · Electromechanical Releasing Devices
- Fire Extinguishing System(s) Switches
- Suppression System(s) Switches
- Fire Alarm Boxes (Pull Stations)
- Heat Detectors Functional
- Fire Gas & Other Detectors
- Interface Equipment
- Special Hazard Equipment

Annually: Automatic Fire Alarm NFPA 72 // ULC 5536

Alarm Notification Devices

- Audible Devices
- Audible Textual Notification Appliances
- Visible Devices

Supervising Station Fire Alarm System & Transmitters • DACT

- DART
- Special Procedures



NFPA 10 REQUIREMENTS



NFPA10 CODE REQUIREMENTS

INSPECTION
TESTING AND
MAINTENANCE

Monthly NFPA 10

Periodic inspection of fire extinguishers shall include a check of at least the following items:

- Location in designated place
- No obstruction to access or visibility
- Operating instructions on nameplate legible and facing outward
- Safety seals and tamper indicators not broken or missing
- · Fullness determined by weighing or "hefting"
- · Examination for obvious physical damage, corrosion, leakage, or clogged nozzle
- · Pressure gauge reading or indicator in the operable range or position
- · Condition of tires, wheels, carriage, hose, and nozzle checked (for wheeled units)

Annually NFPA 10

All work as outlined under "Monthly".

Fire extinguishers shall be subjected to maintenance at intervals of not more than 1 year, at the time of hydrostatic test, or when specifically indicated by an inspection.

A tag approved by the local authority will be placed on the fire extinguisher certifying it is readiness for immediate use. The tag shall be affixed to the extinguisher and should not be removed for a period of one year.

A conductivity test shall be conducted annually on all carbon dioxide hose assemblies. Hose assemblies found to be nonconductive shall be replaced.

Fire extinguishers removed from service for maintenance or recharge shall be replaced by a fire extinguisher suitable for the type of hazard being protected and shall be of at least equal rating.

At the time of the maintenance, the tamper seal of rechargeable fire extinguishers shall be removed by operating the pull pin or securing device. After the applicable maintenance procedures are completed, a new tamper seal shall be installed.



NFPA10 CODE REQUIREMENTS

INSPECTION TESTING AND MAINTENANCE

5-Year Testing NFPA 10

At intervals not exceeding those specified below, fire extinguishers shall be hydrostatically retested. The hydrostatic retest shall be conducted within the calendar year of the specified test interval.

- AFFF (aqueous film-forming foam) 5 Years
- FFFP (film-forming fluoroprotein foam) 5 Years
- · Dry chemical with stainless steel shells 5 Years
- Carbon dioxide 5 Years
 Wet chemical 5 Years

6-Year Maintenance NFPA 10

Every 6 years, stored-pressure fire extinguishers that require a 12-year hydrostatic test shall be emptied and subjected to the applicable maintenance procedures. The removal of agent from halon agent fire extinguishers shall only be done using a listed halon closed recovery system. When the applicable maintenance procedures are performed during periodic recharging or hydrostatic testing, the 6-year requirement shall begin from that date.

Each extinguisher that has undergone maintenance that includes internal examination or that has been recharged shall have a "Verification of Service" collar located around the neck of the container.

12-Year Testing NFPA 10


At intervals not exceeding those specified below, fire extinguishers shall be hydrostatically retested. The hydrostatic retest shall be conducted within the calendar year of the specified test interval.

- Dry chemical, stored-pressure 12 Years
- Halogenated agents 12 Years



RISKS OF NON-COMPLIANCE

FINANCIAL COSTS



Penalties for failing to meet NFPA 25 requirements include:

- Verbal & Written warnings
- Violations, Fines & Summonses
- Loss of ability to occupy a space, and even forced business closure

If a fire protection system is not working properly:

- The fire department will issue a forthwith notice giving owner 24 hours to remediate before issuing summons.
- Can require the owner to pay for fire watch, which is having a qualified individual monitor a facility 24/7 looking for any signs of fire until the system is back in service.



RISKS OF NON-COMPLIANCE

INJURY/LOSS OF LIFE • DAMAGED REPUTATION

In the event of a fire, non-compliance could have severe implications including:

- Injury/Loss of Life
- Damaged reputation as operator of

"unsafe buildings"











BENEFITS OF NFPA 25 COMPLIANCE



- Maximize system integrity to avoid failure
- Ensure fast, effective response in a fire emergency
- Avoid violations, fines, penalties and building closures
- Brand Reputation better buildings attract better tenants, get higher rents

- Avoid risk of voiding insurance policy and subsequent drop by insurer
- Potentially save millions in damages
- NFPA standard can be used to establish an important element in a negligence suit
- Support better payouts on insurance claims

RAEL ALSO DOES ITM FOR NFPA 10 and NFPA 72



RISKS OF NON-COMPLIANCE

LOSS OF INSURANCE



"Standards and fire protection guidelines issued by insurance carriers are generally more stringent than those issued by NFPA."

"The NYC Construction Codes utilize specifically reference standard NFPA 25 of 2011 and will be compared against the current requirements of FM Global Property Loss Data Sheet 2-81"

Source: MG Engineering

- Failure to provide annual test reports to insurance carrier:
- Can result in reduced claim settlement payment.
- Some insurance companies will drop coverage if a building is not adequately protected or maintained.
- Other insurance companies will negotiate insurance pricing based on what upgrades the owner makes to protect the facility from fire loss.



WHAT INSURERS WANT

MOST COMMON TESTS REQUESTED



- Most recent 5 Year Hydrostatic Test
- Annual Fire Pump Test
- Annual Dry system Test (usually in buildings with a garage)
- Monthly Pump Churn & Visual Inspection Log
- Annual backflow preventer
- Installation of a test header (in larger buildings with roof level booster/fire pump) as insurance will not cover flowing water on the roof for testing.

Also Note:

- Any roof level booster/ fire pumps will require the installation of a low-level test header (if not already existing).
- Insurance carriers will not cover flowing large amounts of water on the roof.



WE'RE REDI

RAEL's Technology Platform is REDiSM Readable Equipment Data Interface

Compliance Assurance & Service Validation Platform

RAEL-REDi is the only app-based compliance platform providing real-time, digital validation of work completed as well as proof-of-presence.






COMPLETE FIRE SYSTEM MANAGEMENT

Manage your ITM schedules so your team can focus on daily demands and not worry about compliance.

- **Track** Set and track proper frequencies by asset, system and component level.
- **Simplify** -Track all asset-specific inspections, testing, and maintenance regardless of whether they are handled by RAEL or your internal staff.
- **Monitor** See where you are across your portfolio in real-time with progress snapshots.
- **Leverage** detailed reporting keeps you in compliance with insurance carrier requirements providing support to negotiate lower rates







REDI TO TRACK

REDi Tags provide:



- Real Proof-of-Presence
- Security can't be duplicated, not easily damaged
- Time-stamp validation
- Flexibility reprogrammable, large data capacity
- Ease doesn't require proper lighting or alignment
- Trusted NFC technology used by Apple Pay and Google Pay **≰** Pay








REDI TO MANAGE

REDi Portal provides you and your customers with tools to:

- Get Better Visibility Digital equipment inventory
- Get Real-Time Event History Work Order Status
- Get Proof of Presence/Better Manage Inspections
- validates all ITM services on a single platform
- Streamline compliance Digital Logbook provides redundant, digital backup for NFPA & AHJ Compliance Verification and Reporting, easily export to PDF for printing








REDI TO MANAGE

REDi Portal provides you and your customers with tools to:

- Get Better Visibility Digital equipment inventory
- Get Real-Time Event History Work Order Status
- Get Proof of Presence/Better Manage Inspections
- validates all ITM services on a single platform
- Streamline compliance Digital Logbook provides redundant, digital backup for NFPA & AHJ Compliance Verification and Reporting, easily export to PDF for printing


The REDi platform can be used to manage other trades such as HVAC – fees may apply.







REDI TO MANAGE EQUIPMENT




EQUIPMENT LIST OVERVIEW

- Codification via Category & Type
- Photos
- Asset Searching & Filter Name, ID, Make, Model, Serial, Floor, Physical Location, Trade, Type, Status, Not Tagged
- Parent-Child Asset relationships (i.e. Multi-Asset Systems & Components)
- Activities remaining to perform
- Activities recently performed




Activity Detail: Annual Inspection Timestamp






PORTFOLIO OVERVIEW - SITE LIST VIEW






SINGLE SITE VIEW - WORK ORDER LIST






SINGLE SITE VIEW / ASSET LIST





SINGLE SITE VIEW / SINGLE ASSET





REDI TO MANAGE INSPECTIONS

ACTIVITY DETAIL: ANNUAL INSPECTION REPORT

	spection, Testing & Maintenance of C ency: WO#: 62911		Date: 09/21/2020		Time: 12:12 PM E	Time: 12:12 PM EDT	
Inspected Property : Q348, 28-07 Jackson	Avenue, Long Is	land City	, NY 11101, U	JS	Tag #: EQ000415	534	
Tradesman Name: Alex Walsh	Serial Num	ber:		Floor: Basement	Location:		
Size and Type of Valve: 8" butterfly	Valve Tag:		Valve Tag Color: Green				
Model Number: GD-6865-8N	Year Manufactured: 20		2018	Manufacturer: nibco			
Control valves properly locked or		pection	annual_ins		indicate area served	G	
Control valves properly locked of supervised Control valve identification signs in place			Control valves accessible		Y		
		$ \mathbf{S} $	Control valves accessible Control valves free from external leaks		₹		
Control valves in normal open or closed position Control valves provided with appropriate wrenches		∀	• Control	valves free from ex	kternal leaks	₹	
(A) ((A)	0.11	Lance and the second	-11)				
	O" answers to R/DESIGNATED				Date: <u>09/21/2020 1</u>	L2:12 PM	



SAMPLE - ANNUAL INSPECTION REPORT



Report of Inspection, Testing & N Inspection Frequency: annually	wo#: 1732		Date: 11/06/2023		
Inspected Property: ()	114500	extra de			
Tradesmen Name: Anthony Durso	Tag Name: Stairwell C Floor OB3 Firehose valve				
Tag #: E000206994	Location: Stairwell C				
Valve Tag Color: yellow					
Manufacturer: giacomini					
Custom ID: S12 COF#85749778 EXP 02/07/2	026.S13 COF	#872072	88 FXP 11/17/2025		
043.011 15. 522 001 1103743770 2.41 02,0772	020,525 001	# 07 E 07 E	00 E/1 12/1/2020	_	
Annual Inspection and Testing for Standpipe S • System in service before inspection and testing	ystems	-	Pertinent parties notified before inspection and testing	_	
Adequate drainage provided before flow testing		☑	Cabinet inspected in accordance with NFPA 1962	P	
Hose storage device inspected in accordance with	NEPA 1962	H	Hose inspected in accordance with NFPA 1962		
Dry pipe valve internally inspected (during trip tes		H	Main drain test conducted	F	
Main drain test conducted at low point drain or ma	in drain test	H	Fill flow pressure (residual) < 10 percent reduction from prior or	F	
connection where supply main enters building (where Backflow prevention assembly forward flow test or		E	original test System demand flow was achieved through the device		
Hose nozzle tested in accordance with NFPA 1962	muucusu	H	Hose storage device tested in accordance with NFPA 1962	_	
Hose tested in accordance with NFPA 1962 (3-year	testing	H	Control valves (including backflow and PIVs) operated through full	F	
requirement) PIVs opened until spring or torsion felt in rod			range and returned to normal position PIVs and OS&Ys backed 1/4 turn from full open		
 PIVs opened until spring or torsion feit in rod Forward flow test conducted at maximum rate pos 	elble (enb		 PIVS and OS&TS backed 1/4 turn from full open Forward flow test conducted without measuring flow (device < 2" 		
where connections do not permit full flow test)		V	and outlet sized to flow system demand)		
 Backflow prevention assembly internal inspection (where shortages last more than 1 year and rationin 			Forward flow test satisfied by annual fire pump flow test	✓	
AHJ) • Dry pipe valve trip tested (at full flow every third year)		_	 Backflow preventer flow test conducted as required by the AHJ Separate records of initial air and water pressure, tripping air 		
		Ш	pressure, and dry pipe valve operating conditions available on premises for comparison		
 Current trip test results compared to previous trip 			 Current results correlate with previous results 	V	
Tag showing date of trip test and name of person and organization conducting test attached to valve			 Low temperature alarms tested at beginning of heating season Automatic air pressure maintenance device tested in accordance 		
Hose connection PRVs flow tested at partial flow adequate to		П	with mfg. inst. Hose rack assembly PRVs flow tested at partial flow adequate to		
move valve from seat • Pertinent parties notified of inspection and testing conclusion		V	move valve from seat		
Annual Maintenance for Standpipe Systems		25. 00	The pertinent items above have been completed and the system status	s is a	
 System in service before conducting maintenance 		V	follows: Results		
Pertinent parties notified before conducting maint		✓	Alarm panel is clear N/	A	
 Manual, semiautomatic, or dry standpipe hose cor operates smoothly 		✓	System returned to service N/	A	
 Operating stems of OS&Y (including backflow) val- 	ves lubricated		Y N	ī	
Valves completely closed and reopened		V		_	
 Adequate drainage provided before flow testing Main drain test conducted 					
 Main drain test conducted Low point drains drained prior to onset of freezing 					
conditions					
 Pertinent parties notified after conclusion of maint 	enance	V			



SAMPLE - ANNUAL INSPECTION REPORT



Control Valves

Inspection Frequency: annually WO#: 173212 Date: 11/21/2023

Inspected Property:

Tradesmen Name: Anthony Durso Floor: Floor 2 Tag Name: Stair C floor 2 ABCV

Tag #: EQ00298818

Valve Tag Color: green

Inspector Initial: A D

Custom ID: S12 COF#85749778 EXP 02/07/2026,S13 COF#87207288 EXP 11/17/2025

REP. INITIAL:

valves for Automatic Breach Control Valves		valves (check all that apply): for Automatic Bre	each Control Valves
 Readings indicate valve is set properly 	Yes	 Readings indicate valve is functioning properly 	Ye
· Valve was reset in accordance with manufacturers instructions	Yes	Valve was repaired or replaced	N/
 Readings indicate valve is functioning properly 	Yes	 Readings indicate correct model valve is installed 	at location and
 Valve was repaired or replaced 	N/A	system hydraulic demands are satisfied	
Readings indicate system hydraulic demands are satisfied	Yes		Ye
Valve was reset, repaired or replaced	Yes	Valve was replaced with correct model	N/
Readings indicate system component pressure ratings not exceeded Yes		Readings indicate system component pressure ratings not exceeded	
	N/A		Ye
Valve was reset, repaired or replaced			
Valve was reset, repaired or replaced Annually Tasks Pressure control and reducing valves for A Breach Control Valves	Automatic	Valve was repaired or replaced Annually Tasks Pressure relief valves for Auto Valves	N/ omatic Breach Conti
Innually Tasks Pressure control and reducing valves for A Freach Control Valves		Annually Tasks Pressure relief valves for Auto	N, omatic Breach Cont
Annually Tasks Pressure control and reducing valves for J Breach Control Valves • Static Inlet	Automatic	Annually Tasks Pressure relief valves for Auto Valves	omatic Breach Cont
Annually Tasks Pressure control and reducing valves for A Freach Control Valves • Static Inlet • Static outlet	Automatic 75	Annually Tasks Pressure relief valves for Auto Valves • Inlet pressure	omatic Breach Cont
Annually Tasks Pressure control and reducing valves for J Preach Control Valves • Static incide • Static coulet • Residual liniet	Automatic 75 75	Annually Tasks Pressure relief valves for Auto Valves • Inlet pressure • Side system	omatic Breach Cont ; N, Trip point 7 p
Annually Tasks Pressure control and reducing valves for J Breach Control Valves • Static inclet • Static coulet • Residual inlet	75 75 70	Annually Tasks Pressure relief valves for Auto Valves • Inlet pressure • Side system • Comments	omatic Breach Control N/ Trip point 7
Annually Tasks Pressure control and reducing valves for J Breach Control Valves • Static inclet • Static coulet • Residual inlet	75 75 70	Annually Tasks Pressure relief valves for Auto Valves • Inlet pressure • Side system • Comments • Factory certified gauge kit present	omatic Breach Cont 7, N, Trip point 7 p
Annually Tasks Pressure control and reducing valves for J Preach Control Valves • Static incide • Static coulet • Residual liniet	75 75 70	Annually Tasks Pressure relief valves for Auto Valves Intel pressure Intel pressure Comments Comments Factory certified gauge kit present Trip test conducted successfully	omatic Breach Cont N Trip point 7 p Ye n gauge at time of flo
Annually Tasks Pressure control and reducing valves for J Preach Control Valves • Static incide • Static coulet • Residual liniet	75 75 70	Annually Tasks Pressure relief valves for Auto Valves • Inlet pressure • Side system • Comments • Factory certified gauge kit present • Tip test conducted successfully (PSID) differential pressure trip point reading fron	omatic Breach Conti 77 Trip point 7 p N Ye n gauge at time of flor raive tag
Annually Tasks Pressure control and reducing valves for A	75 75 70	Annually Tasks Pressure relief valves for Auto Valves • Inlet pressure • Side system • Comments • Factory certified gauge kit present • Tip test conducted successfully (PSID) differential pressure trip point reading fron	omatic Breach Control 7 N/ Trip point 7 p N Ye n gauge at time of floo

Date: 11/21/2023







MRAEL MAINTENANCE CORPORATION

Plaza Avenue. +1 516-593-2000

Report of Inspection, Testing & Maintenance of Dry Sprinkler Systems -

3 year

WO#: 173212 Inspection Frequency: annually

Inspected Property:

Tradesmen Name: Anthony Durso Floor: Floor 39 Tag Name: Floor 39 "Stair pressure room" Nitrogen

Tag #: EQ00042372 Location: Floor 39 Fire Pump Room

Valve Tag Color: green

Custom ID: S12 COF#85749778 EXP 02/07/2026.S13 COF#87207288 EXP 11/17/2025

Annually inspection for Dry Sprinkler Systams - 3 year Systam in service on inspection Hangers and seismic bracing appears undamaged and tightly attache Piping appears free of mechanical damage Piping appears free of mechanical damage Piping appears free of corrosion Piping appears free of cesternal loading Sprinklers appear free of corrosion Piping appears free of corrosion Piping appears free of corrosion Sprinklers appear free of foreign materials Sprinklers appear free of foreign materials Sprinklers appear free of corrosion Sprinklers appear free of corrosion Sprinklers appear free of opening Clearance appears to be adequate between sprinklers and building Contents	ustom ID: S12 COF#85749778 EXP 02/07/20.	20,313 COI #07
Hangers and selsmic bracing appears undamaged and tightly attache Piping appears free of mechanical damage Piping appears free of leakage Piping appears free of leakage Piping appears free of corrosion Piping appears free of corrosion Y Sprinkers appear free of paint Sprinkers appear free of paint Sprinkers appear free of physical damage Sprinkers appear free of physical damage Sprinkers appears to be adequate between sprinklers and building	Annually Inspection for Dry Sprinkler Systems -	3 year
Piping appears free of mechanical damage Piping appears free of leakage Piping appears free of caresian Sprinders appear free of paring Sprinders appear free of corrosion Sprinders appear free of paring Caresian Sprinders appear free of paring Sprinders appear properly oriented Clearance appears to be adequate between sprinklers and building	 System in service on inspection 	Y
Piping appears free of mechanical damage Piping appears free of leakage Piping appears free of corrosion Sprinders appear free of paint Sprinders appear free of paint Sprinders appear free of physical damage Sprinders appear free of physical damage Sprinders appears to be adequate between sprinklers and building Sprinders appears to be adequate between sprinklers and building	· Hangers and seismic bracing appears undamaged	and tightly attached
Piping appears free of leakage Piping appears free of corrosion Piping appears free of corrosion Piping appears free of costemal loading Sprinklers appear free of leakage Sprinklers appear free of corrosion Sprinklers appear free of foreign materials Sprinklers appear free of orpit Sprinklers appear free of paint Sprinklers appear free of physical damage Sprinklers appear properly oriented Clearance appears to be adequate between sprinklers and building		Y
Piping appears free of corrosion Piping appears free of external loading Sprinkers appear free of eleakage Sprinkers appear free of corrosion Sprinkers appear free of foreign materials Sprinkers appear free of foreign materials Sprinkers appear free of physical damage Sprinkers appear free of physical damage Sprinkers appear property oriented Clearance appears to be adequate between sprinklers and building	 Piping appears free of mechanical damage 	Y
Piping appears free of external loading Sprinklers appear free of leakage Sprinklers appear free of leakage Sprinklers appear free of corrosion Sprinklers appear free of foreign materials Sprinklers appear free of paint Sprinklers appear free of physical damage Sprinklers appear free of physical damage Sprinklers appear properly oriented Clearance appears to be adequate between sprinklers and building	 Piping appears free of leakage 	Y
Sprinklers appear free of leakage Sprinklers appear free of corosion Sprinklers appear free of foreign materials Sprinklers appear free of paint Sprinklers appear free of paint Sprinklers appear free of paint Sprinklers appear free of physical damage Sprinklers appear properly oriented Clearance appears to be adequate between sprinklers and building	 Piping appears free of corrosion 	Y
Spiniklers appear free of corrosion Spiniklers appear free of freeign materials Spiniklers appear free of freeign materials Spiniklers appear free of paint Spiniklers appear free of physical damage Spiniklers appear properly oriented Clearance appears to be adequate between sprinklers and building	 Piping appears free of external loading 	Y
Sprinklers appear free of foreign materials Sprinklers appear free of paint Sprinklers appear free of physical damage Sprinklers appear free of physical damage Sprinklers appear froe of physical damage Sprinklers appear spoe adequate between sprinklers and building	 Sprinklers appear free of leakage 	
Sprinklers appear free of paint Sprinklers appear free of physical damage Sprinklers appear properly oriented Clearance appears to be adequate between sprinklers and building	 Sprinklers appear free of corrosion 	Y
Sprinklers appear free of physical damage Sprinklers appear properly oriented Clearance appears to be adequate between sprinklers and building	 Sprinklers appear free of foreign materials 	Y
Sprinklers appear properly oriented Clearance appears to be adequate between sprinklers and building	 Sprinklers appear free of paint 	Y
 Clearance appears to be adequate between sprinklers and building 	 Sprinklers appear free of physical damage 	Y
	 Sprinklers appear properly oriented 	Y
		ers and building

Yes Yes




Date: 12/11/2023


Annually Maintenance for Dry Sprinkler Systems - 3 year System in service before conducting maintenance · Pertinent parties notified before conducting maintenance · Adequate drainage provided before flow testing or draining . Operating stems of OS&Y (including backflow) valves lubricated Yes Valves completely closed and reopened Yes · Main drain test conducted · Dry pipe valve interior thoroughly cleaned and parts replaced/repaired

· Grease or other sealing materials not applied to seating surfaces of dry

. Dry pipe system low points drained after operation and before onset of


SAMPLE - MONTHLY INSPECTION REPORT








SAMPLE - MONTHLY INSPECTION REPORT







REDI TO MANAGE COMPLIANCE

REDi Mobile provides Equipment Intelligence and Compliance Management in the Field/Portfolio Level.

For RAEL service personnel, facilities management, and building engineers

- Compliance forms and guidance
- Supportive content (task lists)





LOCAL AHJ




One tap access to equipment-specific inspection, testing & maintenance requirements



REDI MOBILE SCREENS


Home Page




Location Overview



Activities Due per Equipment



Equipment Status - List





REDI TO INTEGRATE

It's easy to add REDi.

RAEL's REDi platform works as a standalone program or can integrate with your existing work order management system

Essentially a 'bolt-on' to your current platform, once set up, it's as easy to use as Apple Pay or Google Pay
























CBRE | facilitysource



EXAMPLE: CORRIGO INTEGRATION

RAEL's REDi platform integrates with the JLL CorrigoPro work order management system





THEY'RE REDI

















































THANK YOU

FOR MORE INFO
CONTACT
PATRICK O'NEILL

PATRICKO@RAELSPRINKLER.COM C: 917-334-6970 O: 516-593-2000 x136